



1010 10th Street Suite 3538 Modesto, CA 95354 Main Number: 209-552-3700 Fax: 209-525-5757 E-mail: fireprevention@stancounty.com Website: http://www.stanoes.com/fire-prevention.shtm

QUARTERLY INSPECTION CHECKLIST FIRE SPRINKLER SYSTEM

The following procedures shall be performed at each required quarterly inspection of a fire sprinkler system. Unless done by a qualified fire sprinkler company an inspection does not normally include testing, disassembling, or removing any sprinkler equipment or component.

CHECK POINTS	CORRECTIVE ACTION					
FIRE SPRINKLER RISER						
"5-Year" required servicing and maintenance passed	contact fire sprinkler company					
due						
Leaking	contact fire sprinkler company					
Earthquake bracing damaged	contact fire sprinkler company					
Gauges damaged	contact fire sprinkler company					
Hydraulic name plate missing or not legible	contact fire sprinkler company					
Gauge valve turned off C						
Objects draped on or hanging from sprinkler piping	remove objects					
Obstructed by shrubs, storage, etc.	remove objects for 3-foot radius					
Water pressure (lower gauge)	record pressure on reverse side of this sheet					
FIRE SPRINKLER HEADS						
Leaking, corroded, painted	contact fire sprinkler company					
Spare heads with wrench (minimum of 6 heads)	contact fire sprinkler company					
Flow obstructed (objects too close to sprinkler head)	remove obstruction					
FIRE ALARM DEVICES						
Visible physical damage (<u>do not test alarm</u>)	contact fire sprinkler company					
FIRE DEPARTMENT CONNECTION						
Gaskets missing or deteriorated	contact fire sprinkler company					
Clapper valves don't close completely	contact fire sprinkler company					
Inlet caps missing	inspect pipe mouth, remove debris, replace caps					
Caps damaged	repair or replace					
Caps do not rotate smoothly	lubricate					
Material inserted into opening	remove (do not push into pipe)					
External objects blocking connection access	remove objects for 3-foot radius					
No identifying sign (showing building served)	replace, repair, attach metal sign					
WATER SYSTEM CONTROL VALVES						
Valves leak	contact fire sprinkler company					
Control wheels/valves not secured in open position	verify fully open, chain with padlock					
Valves obstructed	remove objects for 3-foot radius					

INSPECTION RECORD (CA Fire Code)

This records it to be kept current. All inspector's signatures are signed under penalty of perjury. This record shall be maintained on the premises and be displayed at the system riser or inspector's test valve, whichever is protected from the elements. Retain this record for 5 years after most recent inspection date.

20 QUAF	QUARTERLY INSPECTIONS			20 QUARTERLY INSPECTIONS			
Inspector's Nan	ne: QTR 1st	Pressure	Inspector's I		QTR 1st	Pressure	
	2nd				2nd		
	3rd				3rd		
	4th				4th		
Date: C	Corrections (if any):		Date:	Correcti	ons (if any):		
20 QUAF	RTERLY INSPE	CTIONS	20 QU	IARTERI	LY INSPE	CTIONS	
Inspector's Nan	ne: QTR 1st	Pressure	Inspector's N		QTR 1st	Pressure	
	2nd				2nd		
	3rd				3rd		
	4th				4th		
Date: C	Corrections (if any):		Date:	Correcti	ons (if any):		